

M333 Series

DOUBLE-CONVERSION ONLINE UPS



FEATURES

- Standard 19" Rack Mounted, 2U high, and 22" deep with slides and rear-panel load-bearing bushings.
- Up to (4) four M333-4 Units can be connected and controlled by a single M362-X UPS.
- Supports very long Holdup time; over 2 hours at 1KW and one hour at 2KW (with four M333-4 Battery Packs).
- An ID Resistor allows the Host UPS (M362-X) to automatically identify the type and number of Battery Packs connected to it.
- An ID Resistor allows the Host UPS (M362-X) to automatically identify the type and number of Battery Packs connected to it.
- Internal Electronic Switch removes power from the I/O connectors when not connected to the Host UPS or when the UPS is Off.
- Complies with MIL-STD-167-1 (Type I) and MIL-S-901D Shipboard Shocks and Vibration.
- MS Power Connectors.
- J-STD-001B and IPC-610A Class-3 Workmanship.
- Conformal Coating of PWBs per MIL-I-46058C and IPC-CC-830.
- Uses high quality VRLA cells.

SPECIFICATIONS:

Battery Type	Valve regulated Lead-Acid (Yuasa NPX-25 or equivalent).			
Nominal Voltage	108VDC			
Nominal Capacity	10AH (10hr)			
Hold-up Time (Vs. Load on the M362-X Output) at 25°C.	Output (AC) Power	1KW	1.8KW	2.4KW
	one M333	26 min	13 min	9.5 min
	two M333	60 min	30 min	21 min
	three M333	96 min	48 min	34 min
	four M333	134 min	67 min	48 min

Notes:

1. For other loads between 1KW to 2.4KW the Hold-up time can be estimated using the following formula: Holdup Time(minutes) = 26.5 x (N/KW) 1.17 were KW is the load in KW and N is the number of M333-4 units connected to the UPS.

2. Below 25°C, derate by 1.25% for every 1°C.

INDICATIONS & CONTROLS	Front panel Visual Indication	A Green LED indicates that the Battery Pack is connected to an operating UPS.
	Safety Switch	When the Host UPS is turned Off, or the “Safe to Disconnect” push button on the UPS (M362-X) front panel is depressed, or the cable between the UPS to the Battery Pack is disconnected, power is automatically removed from the I/O connectors of the CF-02EM333
ENVIRONMENT	Temperature	Non-operating: -20 to +70°C Operating: 0 to + 55°C Note: Prolong exposure to temperatures above +40°C will degrade the battery expected life and performances.
	Humidity	Up to 95% (MIL-STD-810F, Method 507.4)
	Altitude	Operating: Up to 10,000 feet. Non-operating: (Air transport) 50,000 feet
	Orientation	May be installed at any orientation.
	Mechanical Shock	MIL-S-901D (Grade A, Class I & 2)
	Vibration	Shipboard Vibration Per MIL-STD-167-1 (Type 1)
	Fungus	Does not support fungus growth, in accordance with the guidelines of MIL-STD-454, Requirement 4.
	Acoustic Noise	Less than 28dBA (no fans or any other moving parts are used).

EMI	MIL-STD-461E	CS114, (Curve 5, Bulk Cable Injection), CS115 (Bulk Cable Injection), RE101, RE102, RS101, RS103. (Surface-Ships and Submarine-Internal application).
	DC Magnetic Field	Tolerates 1600 A/m (per MIL-STD-1399 Section 70)
WEIGHT AND SIZE	In accordance with DWG M333004 (19" Rack-mount, 2U high, 22" deep, weighs 100 Lbs)	

CONNECTORS AND PIN OUT:

J2 – TO NEXT BATT (To additional M333-4 BATT Pack) MS3452W20-27S or Eq		
Des.	Signal	Minimum Wire Size
A	GND	AWG #16
B	IDRES-2	AWG #22
C	Reserved	AWG #22
D	Reserved	AWG #22
E	+BATT	AWG #16
F	+BATT	AWG #16
G	+24VDC	AWG #22
H	BATT-RTN	AWG #16
I	BATT-RTN	AWG #16
J	Reserved	AWG #22
K	24VDCRTN	AWG #22
L	IDRES-1	AWG #22
M	+BATT	AWG #16
N	BATT-RTN	AWG #16

J1 – TO UPS (To the M362-X UPS) MS3452W20-27P or Eq		
Des.	Signal	Minimum Wire Size
A	GND	AWG #16
B	IDRES-2	AWG #22
C	TMPSNS-1	AWG #22
D	TMPSNS-2	AWG #22
E	+BATT	AWG #16
F	+BATT	AWG #16
G	+24VDC	AWG #22
H	BATT-RTN	AWG #16
I	BATT-RTN	AWG #16
J	Reserved	AWG #22
K	24VDCRTN	AWG #22
L	IDRES-1	AWG #22
M	+BATT	AWG #16
N	BATT-RTN	AWG #16

Notes:

1. **Caution !!!** When the M333-4 is connected to an operating UPS, high voltage (120VDC) may appear on J2. To avoid safety hazard J2 should never be left open. If unused, it must be sealed by its tethered protection cap.
2. Up to (4) four M333-4 units can be connected to a single M362-X UPS.
3. For proper operation, all pins of J1 and J2 must be connected.
4. If more than one M333-4 is used, connect the units as shown below.

The wire size is the minimum required. All pins will accept up to AWG #16.

The total cables length between the last M333-4 to the UPS should not exceed 9 feet.



HOW TO ORDER

Standard Part Number	(1)(2)(3) CF-02EM333-0-0-0
----------------------	-------------------------------

Special Options (1)	
-0	None (STD.)

Optional Special Hardware (3)	
-0	None (STD.)

Optional Slides & Load Bearing Pins (2)	
-0	None (STD.)
-1	Pins and Slides: Pins: Jonathan P/N 1005-406 or equivalent (mate with the UPS back panel's bushings) Slides: Actron P/N A5520-23 (or eq.)
-2	Pins only (same as -1).

Notice: Specifications are subject to change without notice. Contact your nearest Amphenol Corporation Sales Office for the latest specifications. All statements, information and data given herein are believed to be accurate and reliable but are presented without guarantee, warranty, or responsibility of any kind, expressed or implied. Statements or suggestions concerning possible use of our products are made without representation or warranty that any such use is free of patent infringement and are not recommendations to infringe any patent. The user should assume that all safety measures are indicated or that other measures may not be required. Specifications are typical and may not apply to all connectors.

AMPHENOL is a registered trademark of Amphenol Corporation.

PRELIMINARY

©2023 Amphenol Corporation REV:



MILITARY HIGH SPEED

40-60 Delaware Avenue
Sidney, NY 13838
amphenol-aerospace.com | amphenolmao.com